

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037
REPORT # 391023036.0
CLIENT # WAT15

DATE SUBMITTED: 10/23/2019

TO: Water Dynamics
9 Valley Forge Drive

Whippany NJ 07981
ATT: Greg Dwyer

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: 1ST FLOOR FOUNTAIN LOWER-PATERSON CITY WATER., ST
PHILIPS PATERSON

DATE SAMPLED: 10/23/2019

TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	10/27/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gsllabs.com/certnjdep.html

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

405970

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037
REPORT # 391023037.0
CLIENT # WAT15
DATE SUBMITTED: 10/23/2019

TO: Water Dynamics
9 Valley Forge Drive

Whippany
ATT: Greg Dwyer

NJ 07981

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: 1ST FLOOR FOUNTAIN UPPER-PATERSON CITY WATER., ST
PHILIPS PATERSON

DATE SAMPLED: 10/23/2019

TIME SAMPLED: 07:32

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	10/27/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

405970

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037
REPORT # 391023038.0

CLIENT # WAT15

DATE SUBMITTED: 10/23/2019

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

TO: Water Dynamics
9 Valley Forge Drive

Whippany NJ 07981
ATT: Greg Dwyer

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: 2ND FLOOR FOUNTAIN-PATERSON CITY WATER., ST PHILIPS
PATERSON

DATE SAMPLED: 10/23/2019

TIME SAMPLED: 07:40

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.001	mg/l	0.015	10/27/19


< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

405970

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037
REPORT # 391023039.0

REPORT OF ANALYSIS

TO: Water Dynamics
9 Valley Forge Drive

CLIENT # WAT15
DATE SUBMITTED: 10/23/2019

Whippany NJ 07981
ATT: Greg Dwyer

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: KITCHEN SINK-PATERSON CITY WATER., ST PHILIPS PATERSON

DATE SAMPLED: 10/23/2019

TIME SAMPLED: 07:45

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	10/27/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html


MCL = Maximum Contaminant Level allowed by State and Federal regulations.

405970

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

REPORT # 390628005.0

CLIENT # WAT15

DATE SUBMITTED: 6/28/2019

TO: Water Dynamics
9 Valley Forge Drive

Whippany NJ 07981

ATT: Greg Dwyer

SAMPLE TYPE: DOMESTIC WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ST., PHILIPS - BEACH ST.

DATE SAMPLED: 6/27/2019

TIME SAMPLED: 08:05

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	7/5/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

398959

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

**REPORT OF
ANALYSIS**

TO: Water Dynamics
9 Valley Forge Drive

Whippany
ATT: Greg Dwyer

NJ 07981

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037
REPORT # 390628001.0

CLIENT # WAT15
DATE SUBMITTED: 6/28/2019

SAMPLE TYPE: DOMESTIC WATER, GRAB SAMPLE

SAMPLE ID:


SAMPLE LOCATION: ST., PHILIPS - 1ST FLOOR FOUNTAIN STATE ST., PATERSON

DATE SAMPLED: 6/27/2019

TIME SAMPLED: 07:40

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	7/5/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.



398959

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037
REPORT # 390628002.0

CLIENT # WAT15

DATE SUBMITTED: 6/28/2019

TO: Water Dynamics
9 Valley Forge Drive

Whippany
ATT: Greg Dwyer

NJ 07981

SAMPLE TYPE: DOMESTIC WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ST., PHILIPS - 1ST FLOOR FOUNTAIN LOWER STATE
ST., PATERSON

DATE SAMPLED: 6/27/2019

TIME SAMPLED: 07:41

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	7/5/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

398959

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901
 Telephone 908-688-8900
 Fax 908-688-8966
 Email: info@gslabs.com
 Internet: www.gslabs.com

Main Lab
 410 Hillside Avenue
 Hillside, New Jersey 07205
 NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)
 Harvey Klein, M.S., Laboratory Director
 Jordan B. Klein, B.A., Exec. Vice President
 Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

Jersey Shore Lab
 54 Main Street
 Waretown, New Jersey 08758
 NJDEP Lab Cert. #15037
REPORT # 390628003.0

TO: Water Dynamics
 9 Valley Forge Drive

CLIENT # WAT15
DATE SUBMITTED: 6/28/2019

Whippany NJ 07981
 ATT: Greg Dwyer

SAMPLE TYPE: DOMESTIC WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ST., PHILIPS - 2ND FLOOR FOUNTAIN STATE ST., PATERSON

DATE SAMPLED: 6/27/2019

TIME SAMPLED: 07:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	7/5/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

398959

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
 Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037
REPORT # 390628004.0

TO: Water Dynamics
9 Valley Forge Drive

CLIENT # WAT15
DATE SUBMITTED: 6/28/2019

Whippany NJ 07981
ATT: Greg Dwyer

SAMPLE TYPE: DOMESTIC WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: ST., PHILIPS - BEACH ST., 1ST FLOOR FOUNTAIN, PATERSON

DATE SAMPLED: 6/27/2019

TIME SAMPLED: 08:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.004	mg/l	0.015	7/5/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

398959

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.