



AQUA PRO-TECH LABORATORIES
 Certified Environmental Testing

Client: Philips Academy
 190 Oliver St.
 Paterson, NJ 07501

APL Order ID Number: 2061278
 Collected : 06/25/2022 12:00
 Received: 06/27/2022

Contact:
 Client Project: Philips Academy

Contact: 07/14/2022 11:56
 Customer Service Rep: Tony Tudda

Analytical Results Summary

Sample Number	Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
2061278-01	Drinking Water		Oliver 3rd FI Staff Bath						
Total Metals									
Copper		EPA 200.8	7/5/22 16:43	7/5/22 16:43	0.125			0.00200	mg/L
Lead		EPA 200.8	7/5/22 16:43	7/5/22 16:43	0.00261			0.00200	mg/L
2061278-02	Drinking Water		Oliver 2nd FI Boys Bath						
Total Metals									
Copper		EPA 200.8	7/5/22 16:46	7/5/22 16:46	0.196			0.00200	mg/L
Lead		EPA 200.8	7/5/22 16:46	7/5/22 16:46	< 0.00200	U		0.00200	mg/L
2061278-03	Drinking Water		Oliver 3rd FI Girls Bath						
Total Metals									
Copper		EPA 200.8	7/5/22 16:48	7/5/22 16:48	0.151			0.00200	mg/L
Lead		EPA 200.8	7/5/22 16:48	7/5/22 16:48	0.00512			0.00200	mg/L
2061278-04	Drinking Water		Oliver 3rd FI Science Lab						
Total Metals									
Copper		EPA 200.8	7/5/22 16:51	7/5/22 16:51	0.970			0.00200	mg/L
Lead		EPA 200.8	7/5/22 16:51	7/5/22 16:51	0.0124			0.00200	mg/L
2061278-05	Drinking Water		Oliver Kitchen						
Total Metals									
Copper		EPA 200.8	7/5/22 16:53	7/5/22 16:53	0.0999			0.00200	mg/L
Lead		EPA 200.8	7/5/22 16:53	7/5/22 16:53	0.00513			0.00200	mg/L

Brian Wood
 Laboratory Director

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
2061278-06	Drinking Water	Oliver 1st FI Deans Office						
Total Metals								
Copper	EPA 200.8	7/5/22 16:56	7/5/22 16:56	0.120			0.00200	mg/L
Lead	EPA 200.8	7/5/22 16:56	7/5/22 16:56	0.00800			0.00200	mg/L
2061278-07	Drinking Water	Oliver 1st FI Girls Bath						
Total Metals								
Copper	EPA 200.8	7/5/22 16:58	7/5/22 16:58	0.0583			0.00200	mg/L
Lead	EPA 200.8	7/5/22 16:58	7/5/22 16:58	0.00505			0.00200	mg/L
2061278-08	Drinking Water	Oliver 1st FI Boys Bath						
Total Metals								
Copper	EPA 200.8	7/5/22 17:06	7/5/22 17:06	0.145			0.00200	mg/L
Lead	EPA 200.8	7/5/22 17:06	7/5/22 17:06	0.00878			0.00200	mg/L
2061278-09	Drinking Water	Oliver C1 2nd FI Girls						
Total Metals								
Copper	EPA 200.8	7/5/22 17:08	7/5/22 17:08	0.337			0.00200	mg/L
Lead	EPA 200.8	7/5/22 17:08	7/5/22 17:08	0.00738			0.00200	mg/L
2061278-10	Drinking Water	C1 Oliver 3 FI Boys Bath						
Total Metals								
Copper	EPA 200.8	7/5/22 17:11	7/5/22 17:11	0.109			0.00200	mg/L
Lead	EPA 200.8	7/5/22 17:11	7/5/22 17:11	0.00977			0.00200	mg/L
2061278-11	Drinking Water	C1 Oliver 3 FI Girls Bath						
Total Metals								
Copper	EPA 200.8	7/5/22 17:13	7/5/22 17:13	0.0494			0.00200	mg/L
Lead	EPA 200.8	7/5/22 17:13	7/5/22 17:13	< 0.00200	U		0.00200	mg/L
2061278-12	Drinking Water	C1 Oliver 2nd FI. Boys Bath						
Total Metals								
Copper	EPA 200.8	7/5/22 17:16	7/5/22 17:16	0.0504			0.00200	mg/L
Lead	EPA 200.8	7/5/22 17:16	7/5/22 17:16	< 0.00200	U		0.00200	mg/L
2061278-13	Drinking Water	State 2nd FI Boys Bath						
Total Metals								
Copper	EPA 200.8	7/5/22 17:18	7/5/22 17:18	0.274			0.00200	mg/L
Lead	EPA 200.8	7/5/22 17:18	7/5/22 17:18	< 0.00200	U		0.00200	mg/L
2061278-14	Drinking Water	State Cleaning Closet 2nd						

Brian Wood
Laboratory Director



Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
2061278-14	Drinking Water	State Cleaning Closet 2nd						
Total Metals								
Copper	EPA 200.8	7/5/22 17:21	7/5/22 17:21	0.123			0.00200	mg/L
Lead	EPA 200.8	7/5/22 17:21	7/5/22 17:21	0.00338			0.00200	mg/L
2061278-15	Drinking Water	Staff Bath 2nd Fl State						
Total Metals								
Copper	EPA 200.8	7/5/22 17:23	7/5/22 17:23	0.233			0.00200	mg/L
Lead	EPA 200.8	7/5/22 17:23	7/5/22 17:23	< 0.00200	U		0.00200	mg/L
2061278-16	Drinking Water	State 1st Fl Boys Bath						
Total Metals								
Copper	EPA 200.8	7/5/22 17:26	7/5/22 17:26	0.373			0.00200	mg/L
Lead	EPA 200.8	7/5/22 17:26	7/5/22 17:26	< 0.00200	U		0.00200	mg/L
2061278-17	Drinking Water	State 1st Fl Cleaning						
Total Metals								
Copper	EPA 200.8	7/5/22 17:28	7/5/22 17:28	0.217			0.00200	mg/L
Lead	EPA 200.8	7/5/22 17:28	7/5/22 17:28	< 0.00200	U		0.00200	mg/L
2061278-18	Drinking Water	State Girls 1st Fl Bath						
Total Metals								
Copper	EPA 200.8	7/5/22 17:36	7/5/22 17:36	0.206			0.00200	mg/L
Lead	EPA 200.8	7/5/22 17:36	7/5/22 17:36	< 0.00200	U		0.00200	mg/L
2061278-19	Drinking Water	State 1st Fl. Staff Bath						
Total Metals								
Copper	EPA 200.8	7/5/22 17:38	7/5/22 17:38	0.261			0.00200	mg/L
Lead	EPA 200.8	7/5/22 17:38	7/5/22 17:38	< 0.00200	U		0.00200	mg/L
2061278-20	Drinking Water	State Kitchen						
Total Metals								
Copper	EPA 200.8	7/5/22 17:41	7/5/22 17:41	0.157			0.00200	mg/L
Lead	EPA 200.8	7/5/22 17:41	7/5/22 17:41	0.00212			0.00200	mg/L
2061278-21	Drinking Water	State Nurse						
Total Metals								
Copper	EPA 200.8	7/5/22 17:43	7/5/22 17:43	0.527			0.00200	mg/L
Lead	EPA 200.8	7/5/22 17:43	7/5/22 17:43	< 0.00200	U		0.00200	mg/L
2061278-22	Drinking Water	State 2nd Fl. Girls						

Brian Wood
Laboratory Director



Analytical Results Summary

Sample Number									
Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units	

2061278-22 Drinking Water State 2nd Fl. Girls

Total Metals

Copper	EPA 200.8	7/5/22 17:46	7/5/22 17:46	0.258			0.00200	mg/L	
Lead	EPA 200.8	7/5/22 17:46	7/5/22 17:46	< 0.00200	U		0.00200	mg/L	

FootNotes

RL - Reporting limit
 MDL - Minimum detection limit
 ND, U - Indicates compound analyzed for but not detected
 J - Indicates estimated value

B - Indicates compound found in associated blank
 E - Concentration exceeds highest calibration standard
 D - Indicates result is based on a dilution
 P - Greater than 25% diff. between 2 GC columns
 H - Indicates a Hold Time violation
 D1 - Sample was Decanted (Dissolved)

Brian Wood
Laboratory Director

